LEGEND	
∅	POWER SOURCE
◪	PULL BOX PREFORMED TYPE 1
▬▬▬	CONDUIT, RIGID (TRENCH)
———	CONDUIT (TRENCH)
▭	WEATHER PROOF GFCI OUTLET

Note: The Contractor shall provide any necessary bonds and insurance required by MoDOT and shall obtain a MoDOT permit prior to construction. This item is subsidiary to other items of work.

℄ RTE. 92 STA. 576+25.16
℄ SAM BARR RD. STA. 10+00.00

575

RTE. 92

PI STA 576+05.60

1'0

EO1

EO2

PB1

PB2

PB3

2" CONDUIT

4" RIDGID CONDUIT

POWER SUPPLY SEE LIGHTING

Install 50' flagpole in center of island

Install flagpole light 10 feet north of flagpole

Install 1" conduit and 3-1c#10 wire to existing GFCI

Install flagpole light 10 feet south of flagpole

Install 1" conduit and 3-1c#10 wire to existing GFCI

Install 1" conduit and 3-1c#10 wire to existing pull box

BUFFALO GRASS SOD

Power supply/Meter enclosure to be installed by Platte Clay Electric Cooperative. Contractor to install 20 amp circuit breaker and 3-1c#10 to PB1. Splice with underground splice to existing wiring in PB1.

SCALE
0 20 40 60

City of Kearney Flagpole Installation

SPECIAL SHEET
ROUNDABOUT @ SAM BARR RD.
LANDSCAPING &
IRRIGATION SYSTEM PROVISIONS
SHEET 22 OF 30

"THIS MEDIA SHOULD NOT BE CONSIDERED A CERTIFIED DOCUMENT."

IF A SEAL IS PRESENT ON THIS SHEET IT HAS BEEN ELECTRONICALLY SEALED AND DATED.

DATE PREPARED 12/14/2012

ROUTE	STATE
92	MO
DISTRICT	SHEET NO.
KC	84

COUNTY: CLAY
JOB NO.: J4P1748
CONTRACT ID.:
PROJECT NO.:
BRIDGE NO.:

DESCRIPTION	DATE

MISSOURI HIGHWAYS AND TRANSPORTATION COMMISSION

105 WEST CAPITOL
JEFFERSON CITY, MO 65102
1-888-ASK-MODOT (1-888-275-6636)